



March 11, 2013

AL'S CONCRETE PRODUCTS, INC.
BRUCE WIESER
800 TOWNHALL ROAD
LA CRESCENT MN 55947

Re: Description: SEWAGE TREATMENT APPARATUS, FILTER CONTAINER/VAULT
Manufacturer: AL'S CONCRETE PRODUCTS, INC.
Product Name: SEDIMENTATION TANK
Model Number(s): INLINE ZABEL FILTER CANISTER
[for approved effluent filter installation]
Product File No: 20130016

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of March 2018.

This approval supersedes the approval issued on April 4, 2008 under product file number 20080200.

This approval is contingent upon compliance with the following stipulation(s):

- This tank must be designed to withstand the pressures to which it will be subjected.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- The capacity of the sedimentation tank is exempt from the minimum capacity requirements of s. SPS 383.15 (3) of the Wis. Admin. Code. This tank capacity must not be included in the septic tank capacity required by s. SPS 383.15 (3) of the Wis. Admin. Code.
- The sedimentation tank must be installed downstream of septic tanks required by s. SPS 383.15 (3) of the Wis. Admin. Code.
- When Zabel filter model A100, A300 or A1800 is installed in this tank, installation must be in accordance with the filter manufacturer's printed instructions and the filter's product approval stipulations. If there is a conflict between the filter manufacturer's printed instructions and the filter's product approval stipulations, the product approval stipulations will take precedence.

AI's Concrete Products Incorporated
March 11, 2013
Page 2 of 2
Product File No.: 20130016

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Glen W. Schlueter
Plumbing Product Reviewer
Department of Safety and Professional Services
Division of Industry Services
Bureau of Technical Services
(608) 267-1401 Phone
(608) 266-2602 Fax
glen.schlueter@wi.gov E-mail